

## **ADDENDUM #2, April 26, 2022**

East 1<sup>st</sup> Street and Alley Reconstruction

City Project # 2004

BID No. 22-99358

### **NOTICE**

This Addendum is issued to modify, explain, or correct the original drawings, specifications and/or previous addenda and is hereby made a part of the Contract Documents. Please attach this Addendum to the specification and note receipt of this Addendum on the Request for Bid.

### **GENERAL**

No changes.

### **DRAWINGS**

No changes.

### **SPECIFICATIONS**

The following section is added to the Special Provisions:

#### **(2521) WALKS**

Walks shall be constructed in accordance with the provisions of MN/DOT 2521 and the following:

Payment for 4" Concrete Walk, 6" Concrete Walk and 6" Concrete Walk Special shall include all costs of root cutting, excavation, disposing of excavated materials, grading, furnishing, placing and compacting the 4 inch Class 5 Aggregate base.

### **RESPONSES TO BIDDER QUESTIONS**

Question #1:

- a. Question: "Does the contractor has access on 1<sup>st</sup> Street from the west?"
- b. Response: No, due to ongoing construction on the Vision Northland project 1<sup>st</sup> Street cannot be accessed from the west.

Question #2:

- a. Question: "Does the contractor have access from the Alley?"
- b. Response: If the contractor obtains access easements from the property owners, the contractor may access the project from the alley side.

END OF ADDENDUM